

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7150-0811:125 Page 1 of 1

CATEGORY: Boxes/Pull Stations

LISTEE: Federal Signal, 2645 Federal Signal Dr., University Park, IL 60466-3195
Contact: *Leonard Steinbeigle (708) 534-3400

DESIGN: Model MPEX noncoded fire alarm box. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 120 VAC, 6 A

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as fire alarm boxes for use with separately listed compatible fire alarm control panels. Suitable for use in Class I, Group C and D, and Class II, Groups E, F, and G, and Class III hazardous locations.

XLF: 7150-1439:100

*Rev. 06-18-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 18, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**